

Acton Water District - PWS 2002000

Summary of Treated Water Per- and Polyfluoroalkyl Substances (PFAS) 2026

Sample Date	Sample Location			
	Clapp/Whitcomb WTP	Central Acton WTP	North Acton WTP	South Acton WTP
January 7, 2026	Not Sampled	Not Sampled	Not Sampled	15.2
January 13, 2026	Not Sampled	Not Sampled	3	Not Sampled
January 28, 2026	Not Sampled	11.6	Not Sampled	Not Sampled
February 4, 2026	Not Sampled	12.5	2.9	Not Sampled
February 18, 2026	Not Sampled	Not Sampled	Not Sampled	14
February 26, 2026	Not Sampled	Not Sampled	Not Sampled	ND
March 18, 2026	Not Sampled	13.8	Not Sampled	ND
April 23, 2026	Not Sampled	Not Sampled	Not Sampled	ND
April 29, 2026	Not Sampled	ND	ND	Not Sampled

Notes:

WTP = Water Treatment Plant

Units are in parts per trillion (ppt) or ng/L

ND = below method detection limit

Not Sampled = PFAS samples are not collected at each WTP on the same date or when a WTP is not producing water for consumption

Results provided are the sum of 6 PFAS Compounds - PFOA, PFOS, PFNA, PFHxS, PFHpA, and PFDA

Exceeds Massachusetts Department of Environmental Protection (MassDEP) Maximum Contaminant Level (MCL) of 20 ppt or ng/L

All treated water data is shared with consumers to be transparent. Not all of the data presented here will meet MassDEP data acceptance standards.